



# Sri Vijnana Vihara English Medium School

(Affiliated to C.B.S.E - New Delhi)

---



## Government of Andhra Pradesh

## A.P. State Disaster Response and Fire Services Department

**Annual Periodical Renewal Fire Certificate**

From:  
District Fire Officer  
Andhra Pradesh, Krishna

To:  
The District Educational Officer,  
Krishna District, Machilipatnam

**File No: 16925/KRI/DEO/2021, Date:06/03/2021**

**Occupancy NoC RC Number: 162/A2/2014**

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Sri Vijnana Vihara English Medium School, represented by B.V.S.S.M.Lakshmi, R.S.No.181/1, 180 / 2, 181 / 5, Enikepadu Village, Vijayawada Rural Mandal, Krishna District - Regarding.**

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
  3. This Office NOC for Occupancy Rc No. 162/A2/2014, Dt.08/01/2016
  4. Renewal NOC For Occupancy 162/A2/2014, Dt.16/03/2020
  5. Online Application for Renewal NOC of B.V.S.S.M.Lakshmi, R.S.No.181/1, 180 / 2, 181 / 5, Enikepadu Village, Vijayawada Rural Mandal, Krishna District - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 05-03-2021.

<< 0 >>

The Management of Sri Vijnana Vihara English Medium School, represented by B.V.S.S.M.Lakshmi, R.S.No.181/1, 180 / 2, 181 / 5, Enikepadu Village, Vijayawada Rural Mandal, Krishna District has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.72464/- vide challan No. 4130799032020, 41317706232020, 41317706232020, Dated 07/01/2021 at Online, Online.

Block - A

,Block - C

,Block - B

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **B.V.S.S.M.Lakshmi R.S.No.181/1, 180 / 2, 181 / 5, Enikepadu Village, Vijayawada Rural Mandal, Krishna District**, subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 08/01/2021 to 07/01/2026.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

1. This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming any proprietary or ownership rights.
2. The occupier/Owner /Builder/Management concerned of the building premises, shall maintain the Fire Prevention and Fire Safety Measures provided in the building as per No Objection Certificate for occupancy at all times for good use by the Occupant (or) Members of Fire Services (or) Both in the event of outbreak of Fire.
3. Further as per G.O.Ms No. 169, Home (Prisons & Fire) Department Dated, 19-12-2019 the management has to submit declaration every year in prescribed format as furnished by Fire Service Department that Fire Prevention and Fire Safety Measures provided are being maintained in good and efficient condition, in accordance with Act and Rules.



16925/KRI/DFO/2021

Your Sincerely,

*[Signature]*  
6/3/2021  
District Fire Officer  
Andhra Pradesh, Krishna

Copy to Management B.V.S.S.M.Lakshmi, Sri Vijnana Vihara English Medium School, R.S.No.181/1, 180 / 2, 181

/ 5, Enikepadu Village, Vijayawada Rural Mandal, Krishna District

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

SRI VIJNANA VIHARA ENGLISH  
MEDIUM SCHOOL, ENIKEPADU

*[Signature]*  
PRINCIPAL  
SRI VIJNANA VIHARA E.M. SCHOOL  
(Affiliated to C.B.S.E., New Delhi)  
ENIKEPADU, VIJAYAWADA (R)

202.83.28.165/noc/home.html#/final\_noc\_r/102176

*[Signature]*  
Administrative Officer

[About US](#)

[About Our](#)

[School](#)

[Academics](#)

[Academic](#)

[Facilities](#)

[Contact US](#)

[Photo Gallery](#)

[School Assembly](#)

[& Prayer](#)

**[Our Vision &  
Mission](#)**  
**[Our Philosophy](#)**

**[School  
Information](#)**  
**[Guidelines](#)**  
**[Curriculum](#)**  
**[Student Facilities](#)**

**[Games &  
Activities](#)**  
**[Celebrations in  
School](#)**